



Riverbend Water Resources District is seeking bids to remove a 230KW generator set and replace it with a new generator set. Refer to the job scope for further specifications of the generator set. Delivery dates for the generator set must be specified in all bids. Complete specification packages must be complied with your sealed bid and are available at www.rwrd.org or Riverbend Water Resources District Office, 228 A Texas Avenue, New Boston, Texas 75570. Interested parties may direct questions to Austin Robnett, Operations Manager 903-831-0091 or 903-701-1402. All bids must be submitted to the address above in a sealed envelope clearly marked "Riverbend Generator Bid". All bids must be received by 3:00 p.m. on November 7th, 2024. Bids will be opened and read aloud at this time at the Riverbend Office. The Riverbend Water Resources District reserves the right to use best value bid tabulation on all proposals, in which we will consider price and warranty of the generator. Riverbend Water Resources District reserves the right to reject any and all proposals.

Job Scope

1. Remove and replace the old generator and transfer switch at Hayes lift station with a new generator and automatic transfer switch.
2. Remove and replace the old wire from the generator to the transfer switch at Hayes lift station with new wire.

Generator Specifications

1. Fuel- Deisel
2. Votage-480
3. Phase-3
4. KiloWatt-230
5. Amps-350

All specifications are minimums; contractors may submit any standard manufactures equipment that exceeds these minimums.